



“ITEM – Consult”
Notified Body for Pressure Vessels
and Pressure Equipments

CE1837

CERTIFICATE

EU TYPE-EXAMINATION - PRODUCTION TYPE

No: 1837-PED- 0245 Rev.01

Manufacturer's Company name and address:	CV Fire – fire fighting equipments manufacturing, sociedade unipessoal, Lda									
Productio site:	Achada grande de tras, Praia, Ilha de Santiago, Cape Verde									
Product/Type designation:	Fire extinguisher: CVF-P06 - PED-0245(27A. 144B. C) CVF-A06L-PED-2045(27A. 144B. 75F)									
Max. Operating Pressure (Mpa):	1,8									
Max. Operating Temperature (°C):	<table border="1"> <thead> <tr> <th>Temperature</th> <th>T_{min}</th> <th>T_{max}</th> </tr> </thead> <tbody> <tr> <td>CVF-P06-PED 0245</td> <td>-20</td> <td>+ 60</td> </tr> <tr> <td>CVF-A06L-PED-2045</td> <td>0</td> <td>+ 60</td> </tr> </tbody> </table>	Temperature	T _{min}	T _{max}	CVF-P06-PED 0245	-20	+ 60	CVF-A06L-PED-2045	0	+ 60
Temperature	T _{min}	T _{max}								
CVF-P06-PED 0245	-20	+ 60								
CVF-A06L-PED-2045	0	+ 60								
Category of the Equipment:	III									
Testing standards	EN 3-7, E 3-8, EN 3-10									
Conformity Report №:	252/08.03.2022									

The “ITEM-Consult” confirms that after carried out procedure “EC Type-examination-modul B”, the examined pressure equipment “fire-extinguisher Type CVF-P06-PED-0245 (27A. 144B. C; CVF-A06L-PED-2045(27A. 144B. 75F)”, fulfill the essential requirements of Directive 2014 /68 /EU, introduced by “Regulation of essential requirements and conformity assessment of pressure equipments.

Validity:: 10 years (26.01.2022)

09.03.2022 r.
Sofia, Bulgaria
(Place and date of issue)

Manager “ITEM-Consult” Ltd:

(eng. L.Vasilev)