



APRAGAZ

Member of
CEOC
INTERNATIONAL

Chaussée de Vilvorde, 156
Vilvoordsesteenweg, 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
<http://www.apragaz.com>
info@apragaz.com



EU TYPE EXAMINATION CERTIFICATE – Production Type

In accordance with the requirements of Module B of the
Pressure Equipment Directive 2014/68/EU

Certificate N°
10/CN/2276-1 Rev. 0

Manufacturer	Name	Ningbo Pingan Fire Fighting Equipment Manufacturing Co., Ltd
	Address	Dongxi Industrial Zone, Liangnong Town Yuyao City, Ningbo

Concerned Productscope: Mobile Fire Extinguishers – Cylinder & Assembly

Type	Model	Diameter (mm)	Volume V (liter)	Design Temp. TS (°C)	Design pressure PS (bar)	Test Pressure PT (bar)	Drawing
Dry Powder	MFTZL25	255	29	-20/+60	17	24.5	TA25-00
	MFTZL30		34				
	MFTZL50	305	58				TA50-00
Foam	MJPTZ50		63	+5 / +60			

Applicable Standard : EN1866-2 : 2014

Reference technical File: PED PA001 Rev.1

The manufacturer is allowed to affix the «CE» mark followed by the notified body n° to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module C2 are fully met.

The approval is valid until 18/10/2030

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the EN1866-2 standard and of the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.

Date : 06/07/2020 Name : B.NEVE Position : General Manager

Notified body identification
number : 0029

Signature

Third Party Authority : APRAGAZ VZW / ASBL

Third Party Authority
reference : 12419P000

